

Passed Items

Portable Appliance Testing

Client: Steve Street		Site: GU21 5QA			Location: MAIN ROOM	
Asset ID: 042113	Description: MIXER			Tested By J MACKINNON	Test Instrument: W43-0153	
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months	
Visual	16/02/2011			Pass		
Insulation Resistance	16/02/2011	> 199	MOhm	Pass		
Overall: Pass						
Asset ID: 042114	Description: BOSE CONTROLLER			Tested By J MACKINNON	Test Instrument: W43-0153	
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months	
Visual	16/02/2011			Pass		
Earth Continuity	16/02/2011	0.034	ohm	Pass		
Insulation Resistance	16/02/2011	> 199	MOhm	Pass		
Overall: Pass						
Asset ID: 042115	Description: LED SPOTLIGHT			Tested By J MACKINNON	Test Instrument: W43-0153	
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months	
Visual	16/02/2011			Pass		
Earth Continuity	16/02/2011	0.066	ohm	Pass		
Insulation Resistance	16/02/2011	> 199	MOhm	Pass		
Overall: Pass						
Asset ID: 042116	Description: LED SPOTLIGHT			Tested By J MACKINNON	Test Instrument: W43-0153	
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months	
Visual	16/02/2011			Pass		
Earth Continuity	16/02/2011	0.082	ohm	Pass		
Insulation Resistance	16/02/2011	> 199	MOhm	Pass		
Overall: Pass						
Asset ID: 042117	Description: SPEAKER			Tested By J MACKINNON	Test Instrument: W43-0153	
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months	
Visual	16/02/2011			Pass		
Earth Continuity	16/02/2011	0.024	ohm	Pass		
Insulation Resistance	16/02/2011	88	MOhm	Pass		
Overall: Pass						
Asset ID: 042118	Description: SPIN LIGHT			Tested By J MACKINNON	Test Instrument: W43-0153	
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months	
Visual	16/02/2011			Pass		
Earth Continuity	16/02/2011	0.038	ohm	Pass		
Insulation Resistance	16/02/2011	> 199	MOhm	Pass		
Overall: Pass						
Asset ID: 042119	Description: SPIN LIGHT			Tested By J MACKINNON	Test Instrument: W43-0153	
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months	
Visual	16/02/2011			Pass		
Earth Continuity	16/02/2011	0.044	ohm	Pass		
Insulation Resistance	16/02/2011	> 199	MOhm	Pass		
Overall: Pass						
Asset ID: 042120	Description: IEC LEAD			Tested By J MACKINNON	Test Instrument: W43-0153	
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months	
Visual	16/02/2011			Pass		
IEC Lead Continuity	16/02/2011	0.046	ohm	Pass		
Insulation Resistance	16/02/2011	> 199	MOhm	Pass		
IEC Lead Polarity	16/02/2011			Pass		
Overall: Pass						
Asset ID: 042121	Description: IEC LEAD			Tested By J MACKINNON	Test Instrument: W43-0153	
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months	
Visual	16/02/2011			Pass		
IEC Lead Continuity	16/02/2011	0.058	ohm	Pass		
Insulation Resistance	16/02/2011	> 199	MOhm	Pass		
IEC Lead Polarity	16/02/2011			Pass		
Overall: Pass						
Asset ID: 042122	Description: SMOKE MACHINE			Tested By J MACKINNON	Test Instrument: W43-0153	
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months	
Visual	16/02/2011			Pass		

Passed Items

Portable Appliance Testing

Earth Continuity	16/02/2011	0.02	ohm	Pass
Insulation Resistance	16/02/2011	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 042123	Description: WINNER LIGHT		Tested By J MACKINNON	Test Instrument: W43-0153
Test Type	Date Tested	Result	Unit	Status
				Retest Period 12 Months
Visual	16/02/2011			Pass
Earth Continuity	16/02/2011	0.068	ohm	Pass
Insulation Resistance	16/02/2011	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 042124	Description: WINNER LIGHT		Tested By J MACKINNON	Test Instrument: W43-0153
Test Type	Date Tested	Result	Unit	Status
				Retest Period 12 Months
Visual	16/02/2011			Pass
Earth Continuity	16/02/2011	0.04	ohm	Pass
Insulation Resistance	16/02/2011	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 042125	Description: ROVER LIGHT		Tested By J MACKINNON	Test Instrument: W43-0153
Test Type	Date Tested	Result	Unit	Status
				Retest Period 12 Months
Visual	16/02/2011			Pass
Earth Continuity	16/02/2011	0.062	ohm	Pass
Insulation Resistance	16/02/2011	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 042126	Description: ROVER LIGHT		Tested By J MACKINNON	Test Instrument: W43-0153
Test Type	Date Tested	Result	Unit	Status
				Retest Period 12 Months
Visual	16/02/2011			Pass
Earth Continuity	16/02/2011	0.046	ohm	Pass
Insulation Resistance	16/02/2011	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 042127	Description: IEC LEAD		Tested By J MACKINNON	Test Instrument: W43-0153
Test Type	Date Tested	Result	Unit	Status
				Retest Period 12 Months
Visual	16/02/2011			Pass
IEC Lead Continuity	16/02/2011	0.026	ohm	Pass
Insulation Resistance	16/02/2011	> 199	MOhm	Pass
IEC Lead Polarity	16/02/2011			Pass
				Overall: Pass

Asset ID: 042128	Description: NUMARK AMP		Tested By J MACKINNON	Test Instrument: W43-0153
Test Type	Date Tested	Result	Unit	Status
				Retest Period 12 Months
Visual	16/02/2011			Pass
Earth Continuity	16/02/2011	0.076	ohm	Pass
Insulation Resistance	16/02/2011	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 042129	Description: 2 GANG EXT LEAD		Tested By J MACKINNON	Test Instrument: W43-0153
Test Type	Date Tested	Result	Unit	Status
				Retest Period 12 Months
Visual	16/02/2011			Pass
IEC Lead Continuity	16/02/2011	0.034	ohm	Pass
IEC Lead Continuity	16/02/2011	0.036	ohm	Pass
Insulation Resistance	16/02/2011	> 199	MOhm	Pass
IEC Lead Polarity	16/02/2011			Pass
				Overall: Pass

Asset ID: 042130	Description: FAN		Tested By J MACKINNON	Test Instrument: W43-0153
Test Type	Date Tested	Result	Unit	Status
				Retest Period 12 Months
Visual	16/02/2011			Pass
Insulation Resistance	16/02/2011	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 042131	Description: 4 GANG EXT LEAD		Tested By J MACKINNON	Test Instrument: W43-0153
Test Type	Date Tested	Result	Unit	Status
				Retest Period 12 Months
Visual	16/02/2011			Pass
IEC Lead Continuity	16/02/2011	0.034	ohm	Pass
IEC Lead Continuity	16/02/2011	0.04	ohm	Pass
IEC Lead Continuity	16/02/2011	0.036	ohm	Pass
IEC Lead Continuity	16/02/2011	0.04	ohm	Pass

Passed Items

Portable Appliance Testing

Insulation Resistance	16/02/2011	> 199	MOhm	Pass
IEC Lead Polarity	16/02/2011			Pass
				Overall: Pass

Asset ID: 042132	Description: 4 GANG EXT LEAD	Tested By J MACKINNON	Test Instrument: W43-0153		
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months
Visual	16/02/2011			Pass	
IEC Lead Continuity	16/02/2011	0.04	ohm	Pass	
IEC Lead Continuity	16/02/2011	0.04	ohm	Pass	
IEC Lead Continuity	16/02/2011	0.042	ohm	Pass	
IEC Lead Continuity	16/02/2011	0.048	ohm	Pass	
Insulation Resistance	16/02/2011	> 199	MOhm	Pass	
IEC Lead Polarity	16/02/2011			Pass	
				Overall: Pass	

Asset ID: 042133	Description: 2 GANG EXT REEL	Tested By J MACKINNON	Test Instrument: W43-0153		
Test Type	Date Tested	Result	Unit	Status	Retest Period 12 Months
Visual	16/02/2011			Pass	
IEC Lead Continuity	16/02/2011	0.42	ohm	Pass	
IEC Lead Continuity	16/02/2011	0.436	ohm	Pass	
Insulation Resistance	16/02/2011	> 199	MOhm	Pass	
IEC Lead Polarity	16/02/2011			Pass	
				Overall: Pass	

Total Tests: 21
